

## Stradbroke Charitable Trust - Legionella Risk Assessment for Stradbroke Surgery

Risk	Assessment	Action to be taken	Date	Signed
Are conditions present which will encourage bacteria to multiply? Is the water between 20°C and 45°C?	No - all cold taps are mains fed. Hot water supplied by small electric heaters adjacent to outlets and thermostats set at 60°C.	Check thermostat settings and water temperature periodically.	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Are water droplets produced e.g. from showers, spa baths etc?	No showers or spas.	None	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Can sediment, sludge, scale, organic material or biofilms build up in the water system	Only storage is small water heaters where scale can build. Thermostats set to 60°C.	Check thermostats.	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Is the water system used regularly (more than once a week)?	Yes	All Practice staff to note and report any changes.	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Are there any units which are not used regularly?	No	All Practice staff to note and report any changes.	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Are there any areas of redundant pipe which will allow water to stagnate?	No	None	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>
Have all cold water storage tanks got lids?	N/A	None	1 <sup>st</sup> March 2019	<i>R.O. Smith</i>